

Hoosick Area

Community Participation Work Group

Hoosick Area CPWG

Water Quality Report

Joshua Magisano, Assistant WTP Operator
Village of Hoosick Falls



New Water Source - LaCroix

- LC1 & LC2 were activated on March 31, 2025



Water Quality Data

Raw Water (quarterly for PFAS) May 2026

- ✓ 3.53 ppt PFOA
- ✓ Non detect for other compounds

Water Quality Data

GAC (monthly for PFAS: pre, mid, post)

- ✓ Pre: 3.53 ppt PFOA
- ✓ Mid: 2.99 ppt PFBA
- ✓ Post: Non detect for PFAS compounds

Water Quality Data

Distribution (daily for disinfection, corrosion, clarity) May 2026

- ✓ Clarity is 0.03 ntu monthly average for May
- ✓ Negative for total coliform and E. coli

Water Quality Report

Available online at:

- ✓ <https://hfvillage.org/2025-annual-drinking-water-quality-report/>